



Yara Balans 26 3 4 SVI

(83020520)



3,78



1,12

Calibration faktor

1,10

Throw distance parameter

17,9

ZA-TS

Attention! An additional cross-check on a mobile test kit is recommended.

ZA-TS / ZG-TS	[Icon]		[Icon]		[Icon]		[Icon]		[Icon]		[Icon]		[Icon]		[Icon]	[Icon]	[Icon]
	15	46	600	A	1	500	1	22	500	1	32	500	20	-5			
TS 1	16	46	600	A	1	500	1	21	500	1	31	500	21	-4	170		
	18	47	600	A	1	500	1	20	500	1	30	500	21	-2	181		
	20	50	600	A	1	720	1	19	600	1	29	500	21	0	217		
	21	52	600	A	1	720	1	18	600	1	28	500	21	0	235		
	24	55	800	A	1	600	1	19	600	1	29	500	26	-2	222		
TS 2	21	22	600	B	2	720	2	27	600	2	37	500	26	-4	170		
	24	22	600	B	3	720	3	26	600	3	36	500	27	-2	170		
	27	25	600	B	3	720	3	23	600	3	33	500	27	0	205		
	28	27	600	B	3	720	3	23	600	3	33	500	27	0	221		
	30	28	720	B	3	800	3	23	720	3	33	600	31	-1	197		
TS 3	24	21	600	C	2	720	2	24	600	2	34	500	31	-5	170		
	27	21	600	C	2	720	2	22	600	2	32	500	31	-3	170		
	28	21	600	C	2	720	2	21	600	2	31	500	31	-2	171		
	30	24	720	C	2	800	2	21	720	2	31	600	35	-3	170		
	32	26	720	C	2	800	2	21	720	2	31	600	35	-2	185		
	33	27	720	C	3	800	3	21	720	3	31	600	35	-2	196		
	36	30	800	C	3	900	3	21	800	3	31	720	38	-1	214		